

7.1 **Roofing**

A. General Requirements

1. Contact the FCCJ Facilities Dept. Roof Manager, Mr. Jack Brede, at 632-3002.
2. Two types of roof are in Standard Use at FCCJ. Other types of roofing occur in such small quantities that they will not be addressed in this document. The intention of FCCJ's Roof Program is to eventually convert all roofs over to one of the two Standard Types.
3. FCCJ Roof Standard Type A: Low Slope Roofing. Roof decks shall be constructed to achieve no less than ¼" per foot of slope-to-drain.

Roof Standard Type A is specified around Siplast Paradiene as a base sheet and cap sheet comprising a two ply modified bitumen application as per the Siplast roofing specifications. Roof Standard Type A includes a warranty of 20 years.

Roof Standard Type B: Pitched Roof With Overhang. Roof structure shall be constructed to achieve a minimum 4 in 12 pitch.

Roof Standard Type B is specified around 2 ½ in. standing seam metal panel roof. Overhang shall be a minimum of 3 ft.